

**KANSAS CITY POWER & LIGHT COMPANY**

Name of Issuing Corporation or Municipality

For Rate Areas No. 1 and No. 3

Community, Town or City

**RECEIVED**  
**MAR 16 1978**  
(continued)  
**MISSOURI**  
**Public Service Commission**

**GENERAL RULES AND REGULATIONS  
APPLYING TO ELECTRIC SERVICE**

**17. EMERGENCY ENERGY CONSERVATION PLAN**

17.01 **ANTICIPATED EMERGENCY:** In the event emergency conditions are anticipated by the Company on its system or on the interconnected electric systems of which the Company's system is a party, which conditions may result in (a) an inability by the Company to meet all electric requirements of its customers, or (b) a general inability by the interconnected systems to meet all electric requirements of customers on the interconnected systems of which the Company's system is a part, due to a lack of (i) available electric generating capacity or (ii) fuels therefor, and an emergency has been duly declared on account thereof by proper State or Federal authorities having jurisdiction, the Company may, upon written notice by the Company to the Commission, implement an Emergency Energy Conservation Plan pursuant to this Rule 17.

17.02 **CUSTOMER NOTIFICATION:** The Company will give prompt notice to its customers of the implementation of this Emergency Energy Conservation Plan by appropriate releases to the news media and, to the extent practical and in accordance with procedures deemed appropriate by the Company, by direct contact (telephonic, written or personal) with its large commercial and industrial customers who will be advised that this Emergency Energy Conservation Plan has been implemented by the Company.

17.03 **EXEMPT FACILITIES:** Customers operating facilities of the type listed in this Rule 17.03 shall be exempt from application of the Company's Emergency Energy Conservation Plan, provided such customers undertake the reduction of electric energy usage to the fullest extent practical consistent with continued operation of such facility to provide the services, functions or activities for which such customer is responsible.

- (a) Any facility whose function is necessary to the support of life, such as, but not limited to,
  - (i) hospital services and nursing homes, or
  - (ii) non-hospital life sustaining facilities, including iron lungs, kidney machines and shaker beds.
- (b) Any facility whose function is necessary for national, state or local security, such as, but not limited to,
  - (i) missile sites,
  - (ii) defense communication network centers,
  - (iii) civil defense facilities,
  - (iv) prisons, or
  - (v) other governmental activities essential to national security.

**FILED**  
**MAR 20 1978**  
**78-203**  
**Public Service Commission**

DATE OF ISSUE March 16, 1978  
month day year

DATE EFFECTIVE March 20, 1978  
month day year

ISSUED BY L. C. Rasmussen  
name of officer

Vice President  
title

1330 Baltimore, Kansas City, Mo.  
address


KCPL FORM 81-101 (REV. 2/78)

Cancelling P. S. C. MO. No. \_\_\_\_\_

{ Original } SHEET No. \_\_\_\_\_  
Rev. No. \_\_\_\_\_  
For Rate Areas No. 1 and No. \_\_\_\_\_  
Community, Town or City \_\_\_\_\_

**KANSAS CITY POWER & LIGHT COMPANY**

Name of Issuing Corporation or Municipality



GENERAL RULES AND REGULATIONS  
APPLYING TO ELECTRIC SERVICE

17. EMERGENCY ENERGY CONSERVATION PLAN (continued)


17.03 EXEMPT FACILITIES: (continued)

- (c) Any facility whose function is necessary to provide essential public services, such as, but not limited to,
  - (i) police and fire control facilities,
  - (ii) essential public services, including water, telephone, gas, trash and sewage services,
  - (iii) transportation facilities,
  - (iv) communications media,
  - (v) fuels and energy supply facilities,
  - (vi) food processing, storage and distribution facilities,
  - (vii) medical supply facilities, or
  - (viii) community centers used to house groups of persons affected by curtailment of electric or other forms of public service.

17.04 DAILY MONITORING: Upon implementation by the Company of its Emergency Energy Conservation Plan under this Rule 17, the Company will monitor daily the need for continuation thereof and/or the need to implement, as the Company in its sole discretion deems appropriate, further action hereunder in the following stages.

17.05 FIRST STAGE CONSERVATION: The first stage in energy conservation will be directed at securing voluntary reductions in energy usage by all Company customers to the extent that such reductions do not endanger health, safety or employment within the Company's service territory, and will include the following:

- (a) The Company will reduce its own usage of electric energy in any way that will not jeopardize essential operations.
- (b) The Company will make public appeals through appropriate news media, asking all customers to voluntarily reduce their usage of electric energy.
- (c) The Company will request all its wholesale electric customers to seek voluntary curtailments on their systems.
- (d) The Company will contact large commercial and industrial customers and request voluntary curtailment of energy without causing work force reductions.



KCPL FORM 81-101 (REV. 2/78)

DATE OF ISSUE March 16, 1978

DATE EFFECTIVE March 20, 1978

ISSUED BY L. C. Rasmussen  
name of officer

Vice President  
title

1330 Baltimore, Kansas City, Mo.  
address


Cancelling P. S. C. MO. No. ....

{ Original } SHEET No. ....  
{ Revised } SHEET No. ....

**KANSAS CITY POWER & LIGHT COMPANY**

Name of Issuing Corporation or Municipality

For Rate Areas No. 1 and No. 9  
Community, Town or City



GENERAL RULES AND REGULATIONS  
APPLYING TO ELECTRIC SERVICE


17. EMERGENCY ENERGY CONSERVATION PLAN (continued)

17.05 FIRST STAGE CONSERVATION: (continued)

- (e) The Company will require elimination of outdoor flood lighting, advertising and decorative lighting, except for the minimum level necessary to protect life and property, and permitting a single illuminated sign identifying commercial facilities that are open after dark.
- (f) The Company will request reduction in parking lot lighting, street and alley lighting, and dusk-to-dawn lighting to minimum functional and safety levels where practical.
- (g) The Company will request adjustment of work schedules for building cleaning, maintenance, restocking, etc., which require office or industrial facilities to be lighted, heated or cooled beyond normal office of plant hours.

17.06 SECOND STAGE CONSERVATION: If further voluntary energy conservation efforts are necessary in the judgment of the Company, it will request its customers to:

- (a) curtail sports, entertainment and recreational activities consistent with energy conservation; e.g., eliminate sports events requiring lighting and close theaters requiring energy for heating or cooling facilities;
- (b) reduce hours of operation, or close, all public museums, art galleries, historic buildings, and other nonessential facilities requiring lighting, heating or cooling;
- (c) reduce usage of electricity in residences, stores, offices and factories to minimum functional and safety levels, by reduction of general lighting levels, the number of elevators operating during non-peak hours and the elimination of show windows, display and other decorative lighting;
- (d) minimize energy usage in all commercial, industrial and residential establishments by maintaining a temperature of no more than 65° F during operation of heating equipment, and no less than 80° during operation of cooling equipment and by reducing the temperature level of heated water to 140° F or less; and



KCPL FORM 8-1-101 (REV. 2/78)

DATE OF ISSUE March 16, 1978  
month day year

DATE EFFECTIVE March 20, 1978  
month day year

ISSUED BY L. C. Rasmussen  
name of officer

Vice President  
title

1330 Baltimore, Kansas City, Mo.  
address

Cancelling P. S. C. MO. No.

KANSAS CITY POWER & LIGHT COMPANY

Name of Issuing Corporation or Municipality

For Rate Areas No. 1 and No. 3

Community, MO. 16 1978

Original  
XEROXED

Original  
Revised

**RECEIVED**

MISSOURI  
Public Service Commission

GENERAL RULES AND REGULATIONS APPLYING TO ELECTRIC SERVICE

(continued)

17. EMERGENCY ENERGY CONSERVATION PLAN (continued)

17.06 SECOND STAGE CONSERVATION: (continued)

- (e) request commercial establishments, i.e., department stores, shopping centers and the like, to operate on a schedule not to exceed six days per week with a maximum of 48 hours of operation per week, and
- (f) request all industrial and commercial facilities, and the City of Kansas City, Missouri, which are known to have emergency reduction plans, to implement such plans.

17.07 MANDATORY CURTAILMENT: In the event that the voluntary energy conservation measures implemented under Rules 17.05 and 17.06 hereof are not adequate, in the judgment of the Company, to achieve the necessary level of energy conservation on its system, the Company may, at its discretion, request the Commission to approve mandatory energy curtailment under this Rule 17.07. Upon receipt of such Commission approval, the provisions of Rules 17.05 and 17.06 shall become mandatory and binding on all the Company's customers. In the event of failure by any customer to comply thereafter with the provisions of this Rule 17.07, electric service to such customer may be discontinued by the Company unless the facilities are exempt under Rule 17.03 hereof. Additionally, the following mandatory energy curtailment steps may be implemented as requested by the Company and approved by the Commission:

- (a) effect system voltage reductions up to 5%;
- (b) deenergize circuits on a manual rotation basis, except circuits which include exempt facilities under Rule 17.03 hereof;
- (c) direct industrial customers with relatively few employees, but large electric energy usage, to cease operations, except as necessary for safety and security;
- (d) direct all other industrial customers to curtail monthly usage of electric service by at least 30% of their respective average monthly usage during the preceding 12 full calendar months;
- (e) direct all commercial customers to curtail their monthly usage of electric service to a maximum equivalent to not more than 40 hours per week of their respective normal operations; and

**FILED**

MAR 20 1978

78 - 203

Public Service Commission

DATE OF ISSUE March 16, 1978

DATE EFFECTIVE March 20, 1978

ISSUED BY L. C. Rasmussen

Vice President

1330 Baltimore, Kansas City, Mo.

KCPL FORM 81-101 (REV. 2/78)

Cancelling P. S. C. MO. No. \_\_\_\_\_

{ Original

SHEET No. \_\_\_\_\_

**KANSAS CITY POWER & LIGHT COMPANY**

Name of Issuing Corporation or Municipality

For Rate Areas No. 1 and No. \_\_\_\_\_

Community, Town or City \_\_\_\_\_

**RECEIVED**  
**MAR 16 1978**  
**MISSOURI**  
**Public Service Commission**

GENERAL RULES AND REGULATIONS  
APPLYING TO ELECTRIC SERVICE

17. EMERGENCY ENERGY CONSERVATION PLAN (continued)

17.07 MANDATORY CURTAILMENT: (continued)

(f) direct all industrial and commercial customers to further curtail usage of electric service, on a progressive reduction basis, as may be required to that level needed for employee and plant safety and security.

17.08 LIABILITY OF COMPANY: The Company shall not be considered in default of its service agreement and shall not otherwise be liable to any customer or other person by reason of implementation by the Company of any or all of the procedures described in this Rule 17.

KCPL FORM 81-101 (REV. 2/78)

**FILED**  
**MAR 20 1978**  
**78-203**  
**Public Service Commission**

DATE OF ISSUE March 16, 1978  
month day year

DATE EFFECTIVE March 20, 1978  
month day year

ISSUED BY L. C. Rasmussen  
name of officer

Vice President  
title

1330 Baltimore, Kansas City, Mo.  
address