

**ANNUAL INSPECTION OF CCR LANDFILL BY QUALIFIED PROFESSIONAL ENGINEER  
40 CFR 257.84**

**FACILITY INFORMATION**

Facility Name/ Address	La Cygne Generating Station / 25166 East 2200 Road La Cygne, Kansas 66040
Owner Name	Kansas City Power & Light Company
CCR Unit	CCR Landfill
Inspection Date	January 5, 2016

**ANNUAL CCR UNIT INSPECTION REPORT**

Rule	Inspection Results
(b)(1)(i) – Review of available information regarding the status and condition of the CCR unit.	Seven day inspection reports prepared by a qualified person were reviewed. No issues of concern were noted.
(b)(1)(ii) – Visual inspection of the CCR unit to identify signs of distress or malfunction.	Visual inspection by a qualified professional engineer was made on January 5, 2016. No signs of distress or malfunction were noted.
(b)(2)(i) – Changes in geometry of the structure since the previous annual inspection.	None. This is the first inspection by a qualified professional engineer under the CCR rule.
(b)(2)(ii) – Approximate volume of CCR contained in the unit at the time of the inspection.	Approximately 7.8 million cubic yards.
(b)(2)(iii) – Appearances of an actual or potential structural weakness of the CCR unit, in addition to any existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit.	None. An inspection made in person found no appearances of an actual or potential structural weakness of the CCR unit or existing conditions that are disrupting or have the potential to disrupt the operation and safety of the CCR unit.
(b)(2)(iv) – Other change(s) which may have affected the stability or operation of the CCR unit since the previous annual inspection.	None. This is the first inspection by a qualified professional engineer under the CCR Rule

**QUALIFIED PROFESSIONAL ENGINEER**

Prepared by	Brian D. Linnan
Date	January 19, 2016
Signature	

